

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Satisfactory

Email Address(es): tequigley@dadeschools.net;
ccoffey@dadeschools.net

Violations Comments

Violation #5. Maintenance & Repair
-Replace and provide missing tiles inside of classrooms #005 and #012.
-Replace light bulbs burned-out in classrooms #010, #107, #123B, and #128.
CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Inspection Conducted By: Lucia Gonzalez Melendez (913031)
Inspector Contact Number: (786) 676-2013
Print Client Name: Pine Lake El.
Date: 3/4/2020

Inspector Signature:

Handwritten signature of Lucia Gonzalez Melendez.

Client Signature:

Handwritten signature of J. Rodriguez.